

MODEL AXF-12


12" [305mm] ACOUSTICAL LOUVER

STANDARD CONSTRUCTION:

- Frame:** 12" [305mm] Deep x 18 gauge galvanized steel
 - Blade (air side):** 18 gauge galvanized steel
 - Blade (noise side):** 20 gauge galvanized perforated steel
 - Sound Absorber:** Advanced Microfibers composed of Polyester and Polyolefin
 - Screen:** 0.75" x 0.051" [19mm x 1.29mm] flattened aluminum screen mounted in removable frames.
 - Minimum Louver Size:** 12"w x 24"h [305mm x 610mm]
 - Maximum Louver Size:** 48"w x 120"h [1219mm x 3048mm]
- Louvers more than 48" [1219mm]w are built in mult. sections

OPTIONS:

- Screen mounted: Exterior Side
- Flanged Frame (1.5" [38mm] std.)
- Custom Flange (1", 2" , or 3") [25mm, 51mm, or 76mm]
- Extended Sill
- Insect Screen (Other Screens Available, See Screen Page)
- Filter Racks (no screen)
- Security Bars
- Hinged Sub Frame
- Welded Construction
- Blank-off, Steel, non-insulated, no screen, non-removeable
- Blank-off, Steel, non-insulated, with bird screen or insect screen
- Blank-off, Steel, insulated double wall, with bird screen, removable
- Blank-off, Steel, insulated double wall, no screen, non-removeable
- Aluminum Construction
- 304 Stainless Steel Const. 316 Stainless Steel Const.



Model AXF-12
FREE AREA: 30% (based on size 48" x 48") [1219mm x 1219mm]

AVAILABLE FINISHES:

- Durable Polyester Powder (AAMA 2604)
- Epoxy Powder
- Zinc Rich Gray Primer

Model AXF-12

Acoustical Performance Certified data by Riverband Acoustical Laboratories

Selected 1/3 Octave Band Center Frequency HZ	125	250	500	1000	2000	4000
Transmission Loss in Decibels	6	5	8	11	10	8
Free Field Noise Reduction	12	11	14	17	16	14
						STC = 9

*Width and Height dimensions are approximately 1/4" [6.35mm] under listed size.

Due to continuing research, United Enertech reserves the right to change specifications without notice.

	3005 South Hickory Street Chattanooga, Tennessee 37407 Tel: (423) 698-7715 Fax: (423) 698-6629 www.unitedenertech.com					
	<p>MODEL AXF-12 (12" [305mm] ACOUSTICAL LOUVER)</p>					
DRAWN BY: MHM	DATE: 4-21-10	REV. DATE: 2-25-14	REV. NO. 4	APPROVED BY: BGT	DWG. NO.: A-35	